

Manufacturer's declaration

On UK Statutory Instrument 2016 No. 1107 HEALTH AND SAFETY The Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016

The company Eisele GmbH declares that all catalogue products with exception of series 1600 and 3800 are not included in the UK Statutory Instrument 2016 No. 1107, as they are neither „equipment and protective systems“ according to article 3, paragraph (2)(a) nor „safety devices, controlling devices and regulating devices“ according to article 3, paragraph (2)(b). Furthermore, the components are not subject to the scope of the Directive, as the components are not explicitly intended for use in equipment and protective systems intended for use in potentially explosive atmospheres (Article 3, paragraph (2)(c)).


The 1600 and 3800 series of the „Freeline“ product line fall within the scope of Article 3, paragraph (2)(c) of the UK Statutory Instrument 2016 No. 1107. The evaluation of potential ignition sources according to DIN EN ISO 80079-36 for both series mentioned above shows that the products do not have a „potential ignition source“ of their own. Therefore, no declaration of conformity is required for these products when used in potentially explosive atmospheres.

When installing catalogue products or Series 1600 and 3800 in equipment and protective systems for intended use in potentially explosive atmospheres, an ignition risk assessment of the entire system must be carried out by the customer.

It is recommended to include the following information in the customer's ignition source analysis of the entire system. Depending on application and especially when using electrical products, further influencing factors may have to be considered.

1. The ignition risk depends on the use.
Assembly and disassembly should also be performed if an explosive atmosphere can be excluded.
2. The projected surfaces of all polymeric seals are smaller than 2000 mm².
3. Spiral springs used to reset the pistons/valves have a maximum potential energy of less than 60 joules.
4. The connected hose must also be considered in the analysis of the entire system.

Waiblingen, the 20.09.2021


Johannes Jeitler
Managing director